


SPECIFICATION FOR REQUIREMENT OF SECURITY GUARDS : APS JAMMU CANTT

1. 04 x Security Guards (Ex-Servicemen) without arms

2. 02 x Security Guards (Ladies) without arms

} Age below 60 Years


Principal
Army Public School
Jammu Cantt

NAME OF WORK :- SITC of Fire hydrant system.

S No	DESCRIPTION OF ITEMS	Qty
1	SITC of M.S Pipes (B class) of following sizes: (mtr)	
	a) 80 mm dia	330
	b) 50 mm dia	172
	c) 25 mm dia	50
2	SITC of single headed hydrant valve with 80mm dia flanged inlet and 63mm dia outlet complete .	2
3	Supply of flexible hose RRL 63mm dia x 15 mtr long complete with 63mm dia male and female coupling .	4
4	Supply of 63mm dia short branch pipe.	2
5	SITC of First aid hose reel wall mounting & 20 mm dia 30 mtr long hose with shut off nozzle complete as req.	18
6	SITC of CI Butterfly valve of following sizes:	
	a) 50 mm dia	10
	b) 80 mm dia	4
7	SITC of following accessories:	
	a) 25mm dia spring loaded air release valve.	8
	b) 25 mm dia ball valve.	10
	c) Pressure Guage	1
8	Hose box	2
9	15Hp pump with starter	1
10	S/l of 4 x 16 sqmm Aluminium armoured cable	20
11	SITC of 80 mm dia NRV	2
12	SITC of 2 way Fire Brigade Connection (FBD)	2
13	4.5 kg CO2 type Fire Extinguisher	4
14	2 Hp motor pumpset	2



Principal
Army Public School
Jammu Cantt